



April 1, 2021

Generac Power Systems, Inc.  
Sie Teong Lim  
Product Manager Residential Transfer Switches

SUBJECT: Generac Panel ATS Approval

To Sie Teong Lim,

The following sockets/transfer switches are acceptable to OPPD:

- RXGUW200A3
- RXUW200A3 and RXUW150A3
- RBU200A3 and RBU150A3

One requirement we do have is that these will not be acceptable with the horn bypass option.

Sincerely,

*Seth McClintock*

Seth McClintock, P.E.  
Senior Design Engineer  
Engineering Division  
Omaha Public Power District